

REGIONAL WATER TESTING LAB, SAS NAGAR

Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab
mdlsasnagar@gmail.com

To,

SHAHEED BABU SINGH PUBLIC SCHOOL
Village Tewar, Tehsil Kharar, Distt. MOhali

No.: RWTLSAS/2425/00159 Dated : 07/08/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Ref. No. SBS/TEW/017/2024-25 Dated: 30/07/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 30/07/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, SAS Nagar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
SAS Nagar

REGIONAL WATER TESTING LAB, SAS NAGAR


Water Works Complex, Phase- 2 , S.A.S NAGAR , Punjab
mdlsasnagar@gmail.com

TEST REPORT						
Name & Address of Customer : SHAHEED BABU SINGH PUBLIC SCHOOL Village Tewar, Tehsil Kharar, Distt. MOhali			Customer Reference No.		No : Ref. No. SBS/TEW/017/2024-25 Dated : 30/07/2024	
			Sample Submitted by		Gurmeet Singh	
			Date of Sample Receipt		30/07/2024	
			Analysis Starting Date		30/07/2024	
			Analysis completion Date		05/08/2024	
Discipline : Bacteriological Testing			Group: Water			
ULR No.:				Sample Type :		Treated Water
Test Report No.:		RWTLSAS/2425/00159		Date of Issue :		07/08/2024
Registration no.:		RWTLSAS/REG2425/00828		Condition of Sample :		Unsealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		750 ml / Amber Colored Glass Bottle
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		SHAHEED BABU SINGH PUBLIC SCHOOL, Village Tewar, Tehsil Kharar, Ground floor (Water Cooler) / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		SAS Nagar
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Manik Kataria
Sr. Chemist
Authorized Signatory
For,Regional Water Testing Lab
SAS Nagar

----- End of the Test Report -----